

Site Emissions Monitoring Data

Licensee	Foamco Industries Pty Ltd				Updated	12th May 2021			
Site	27 Pembury Road, Minto, NSW, 2170				Licence No	4244			
EPA Sampling Point	Monitoring Frequency	Date Sampled	Date Obtained	Date Published/Updated	Pollutant	Limit	Measured	Units	Exceed Y/N
2	Annual	17/01/2018			2,4 & 2,6 isocyanate combined	0.002	0.0005	mg/m3	N
3	Annual	18/01/2018			2,4 & 2,6 isocyanate combined	0.008	0.0041	mg/m3	N
4	Annual	17/01/2018			2,4 & 2,6 isocyanate combined	0.008	0.0003	mg/m3	N
1	Annual	21/02/2019			2,4 & 2,6 isocyanate combined	0.08	0.0028	mg/m3	N
					Methylene Chloride	1	0.99	g/m3	N
2	Annual	3/04/2019			2,4 & 2,6 isocyanate combined	0.002	0.002	mg/m3	N
3	Annual	21/02/2019			2,4 & 2,6 isocyanate combined	0.008	0.0006	mg/m3	N
4	Annual	22/02/2019			2,4 & 2,6 isocyanate combined	0.008	0.0007	mg/m3	N
1	Annual	27/11/2019	26/03/2020	10/08/2020	2,4 & 2,6 isocyanate combined	0.08	0.0008	mg/m3	N
	Annual	27/11/2019	26/03/2020	10/08/2020	Methylene Chloride	1	0.73	g/m3	N
	Annual	27/11/2019	26/03/2020	10/08/2020	Benzene		0.3	mg/m3	
	Annual	27/11/2019	26/03/2020	10/08/2020	Gry Gas density		1.29	Kg/m3	
	Annual	27/11/2019	26/03/2020	10/08/2020	Fine Particles		4.6	mg/m3	
	Annual	27/11/2019	26/03/2020	10/08/2020	Moisture		1.8	%v/v	
	Annual	27/11/2019	26/03/2020	10/08/2020	Temperature		296	K	
	Annual	27/11/2019	26/03/2020	10/08/2020	Velocity		19	m/s	
	Annual	27/11/2019	26/03/2020	10/08/2020	Volumetric Flow rate		4.5	m3/s	
2	Annual	26/11/2019	26/03/2020	10/08/2020	2,4 & 2,6 isocyanate combined	0.002	0.002	mg/m3	N
	Annual	26/11/2019	26/03/2020	10/08/2020	Benzene		0.08	mg/m3	
	Annual	26/11/2019	26/03/2020	10/08/2020	Gry Gas density		1.29	Kg/m3	
	Annual	26/11/2019	26/03/2020	10/08/2020	Fine Particles		<1	mg/m3	
	Annual	26/11/2019	26/03/2020	10/08/2020	Moisture		2.2	%v/v	
	Annual	26/11/2019	26/03/2020	10/08/2020	Temperature		309	K	
	Annual	26/11/2019	26/03/2020	10/08/2020	Velocity		15	m/s	
	Annual	26/11/2019	26/03/2020	10/08/2020	Volumetric Flow rate		13	m3/s	
3	Annual	27/11/2019	26/03/2020	10/08/2020	2,4 & 2,6 isocyanate combined	0.008	0.0079	mg/m3	N
	Annual	27/11/2019	26/03/2020	10/08/2020	Benzene		0.07	mg/m3	
	Annual	27/11/2019	26/03/2020	10/08/2020	Gry Gas density		1.3	Kg/m3	
	Annual	27/11/2019	26/03/2020	10/08/2020	Fine Particles		<3	mg/m3	
	Annual	27/11/2019	26/03/2020	10/08/2020	Moisture		0.88	%v/v	
	Annual	27/11/2019	26/03/2020	10/08/2020	Temperature		297	K	
	Annual	27/11/2019	26/03/2020	10/08/2020	Velocity		17	m/s	
	Annual	27/11/2019	26/03/2020	10/08/2020	Volumetric Flow rate		4.1	m3/s	
4	Annual	26/11/2019	26/03/2020	10/08/2020	2,4 & 2,6 isocyanate combined	0.008	0.0077	mg/m3	N
	Annual	26/11/2019	26/03/2020	10/08/2020	Benzene		0.02	mg/m3	
	Annual	26/11/2019	26/03/2020	10/08/2020	Gry Gas density		1.3	Kg/m3	
	Annual	26/11/2019	26/03/2020	10/08/2020	Fine Particles		<3	mg/m3	
	Annual	26/11/2019	26/03/2020	10/08/2020	Moisture		2.2	%v/v	
	Annual	26/11/2019	26/03/2020	10/08/2020	Temperature		307	K	
	Annual	26/11/2019	26/03/2020	10/08/2020	Velocity		18	m/s	
	Annual	26/11/2019	26/03/2020	10/08/2020	Volumetric Flow rate		4.2	m3/s	
1	Annual	22/01/2021	26/04/2021	10/05/2021	2,4 & 2,6 isocyanate combined	0.08	0.0008	mg/m3	N
	Annual	22/01/2021	26/04/2021	10/05/2021	Methylene Chloride	1	0.46	g/m3	N
	Annual	22/01/2021	26/04/2021	10/05/2021	Benzene		<.07	mg/m3	
	Annual	22/01/2021	26/04/2021	10/05/2021	Dry Gas density		1.29	Kg/m3	
	Annual	22/01/2021	26/04/2021	10/05/2021	Fine Particles		<3	mg/m3	
	Annual	22/01/2021	26/04/2021	10/05/2021	Moisture		2.1	%v/v	
	Annual	22/01/2021	26/04/2021	10/05/2021	Temperature		297	K	
	Annual	22/01/2021	26/04/2021	10/05/2021	Velocity		22	m/s	
	Annual	22/01/2021	26/04/2021	10/05/2021	Volumetric Flow rate		5.2	m3/s	
2	Annual	12/02/2021	26/04/2021	10/05/2021	2,4 & 2,6 isocyanate combined	0.002	0.001	mg/m3	N
	Annual	12/02/2021	26/04/2021	10/05/2021	Benzene		0.04	mg/m3	
	Annual	12/02/2021	26/04/2021	10/05/2021	Dry Gas density		1.29	Kg/m3	
	Annual	12/02/2021	26/04/2021	10/05/2021	Fine Particles		2	mg/m3	
	Annual	12/02/2021	26/04/2021	10/05/2021	Moisture		1.8	%v/v	
	Annual	12/02/2021	26/04/2021	10/05/2021	Temperature		305	K	
	Annual	12/02/2021	26/04/2021	10/05/2021	Velocity		14	m/s	
	Annual	12/02/2021	26/04/2021	10/05/2021	Volumetric Flow rate		11	m3/s	
3	Annual	22/01/2021	26/04/2021	10/05/2021	2,4 & 2,6 isocyanate combined	0.008	0.002	mg/m3	N
	Annual	22/01/2021	26/04/2021	10/05/2021	Benzene		0.02	mg/m3	
	Annual	22/01/2021	26/04/2021	10/05/2021	Dry Gas density		1.29	Kg/m3	
	Annual	22/01/2021	26/04/2021	10/05/2021	Fine Particles		<3	mg/m3	
	Annual	22/01/2021	26/04/2021	10/05/2021	Moisture		1.8	%v/v	
	Annual	22/01/2021	26/04/2021	10/05/2021	Temperature		304	K	
	Annual	22/01/2021	26/04/2021	10/05/2021	Velocity		15	m/s	
	Annual	22/01/2021	26/04/2021	10/05/2021	Volumetric Flow rate		3.6	m3/s	
4	Annual	12/02/2021	26/04/2021	10/05/2021	2,4 & 2,6 isocyanate combined	0.008	0.0004	mg/m3	N
	Annual	12/02/2021	26/04/2021	10/05/2021	Benzene		0.03	mg/m3	
	Annual	12/02/2021	26/04/2021	10/05/2021	Dry Gas density		1.29	Kg/m3	
	Annual	12/02/2021	26/04/2021	10/05/2021	Fine Particles		<3	mg/m3	
	Annual	12/02/2021	26/04/2021	10/05/2021	Moisture		2.2	%v/v	
	Annual	12/02/2021	26/04/2021	10/05/2021	Temperature		309	K	
	Annual	12/02/2021	26/04/2021	10/05/2021	Velocity		17	m/s	
	Annual	12/02/2021	26/04/2021	10/05/2021	Volumetric Flow rate		4	m3/s	

Link to EPA

<https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4244&id=4244&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=issued>